NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 17 - APPLICATION OF STATE SERIAL NUMBERS

- 001. This chapter is adopted pursuant to Neb. Rev. Stat. §48-727.
- 002. Upon completion of the installation of a boiler or pressure vessel, or at the time of the initial Certificate inspection of an existing installation, each boiler or pressure vessel shall be identified by a number unique to that item. Stamping of the state serial number in the base metal of the unit shall only be done if the original code of construction allows stamping of the base metal for the actual thickness or material of the metal used in the construction of the unit. As an alternative to stamping, boilers or pressure vessels may have a corrosion- resistant metal tag or some other type of labeling device acceptable to the Commissioner attached in the proximity of or by the original nameplate.
- 003. The stamping or tagging shall not be concealed by lagging or paint and shall be exposed at all times unless a suitable record is kept of the location of the stamping so that it may be readily uncovered at any time.

229 NAC 17 Page 1 of 1